RESIDENTIAL REPLACEMENT FORCED AIR FUEL FIRED APPLIANCE

NEW CASTLE COUNTY

2006 IMC Self-Certification Form

DEPARTMENT OF LAND USE
87 READS WAY, NEW CASTLE, DE 19720
PHONE: 302-395-5400 • WWW.NCCDELU.ORG

REV 2/13/07DAN
REV 11/16/08DAN 2006 IMC
CODE "RRA"

This certification form shall be signed by the Licensed Contractor who performed the installation and the property owner. Completed forms must be forwarded to the New Castle County Inspections Division immediately following the installation. (Inspections fax 395-5116)

LOT # _____ SUBDIVISION_____TAX PARCEL_____

PROPERTY ADDRESS _____

HVAC PERMIT #_____ _____

CHECKLIST

Installations shall comply with all approved applicable codes

Specs: _____ BTU Manuf._____ Model #_____

Fuel type ☐ Natural Gas ☐ LP ☐ Oil ☐ With A/C ☐ A/C not applicable

General / Inspection checklist

Passed	N/A		
☐		Manufacturer's instructions left with appliance	IMC 304.1
☐		Manufacturer's name, model, etc affixed to appliance	IMC 301.6
☐		Appliance installed in accordance with permit	Chpt 6 6.03.013 B6
☐	☐	Lighting fixture installed (attic & under floor spaces)	IMC 306.3.1
☐	☐	Electrical work installed & inspected if applicable	DE Title 24 Ch. 14
☐	☐	Chimney and/or vent connector in good condition or replaced	IMC 803
☐	☐	Chimney and/or vent connector minimally pitched & properly sized	IMC 803.10.5, 801.6
☐	☐	Masonry chimneys lined per	IMC 801.16, IFGC 504.2.9
☐	☐	Direct-vent, integral & mechanical draft systems installed to code	IMC 804
☐		Condensate disposal installed per code	IMC 307, C6 P301.9
☐		Access and service space per code	IMC 306
☐		Piping supported per code	IMC 305
☐		Air filters located, installed, and of approved type	IMC 605

Gas

Passed	N/A		
☐		Shut off valves installed	IFGC 409.1
☐		Fuel gas piping inspected if req'd	IFGC 406.1
☐		Clearance to combustibles	IMC 304.8, 308
☐		Combustion air provided	IMC 701
☐	☐	Ignition source elev. in hazard. locations	IMC 304.3
☐	☐	Oil tank removed if req'd	

Oil

Passed	N/A		
☐		Shut off valves installed	IMC 1307
☐		Fuel oil piping complies with code	IMC 1302
☐		Clearance to combustibles meets code	IMC 304.8, 308
☐		Combustion air provided	IMC 701
☐	☐	Ignition source elev. in hazard. locations	IMC 304.3
☐		Barometric damper installed	IMC 803.6
☐		Fuel oil tank and piping installed per code	Chpt.6 M1301.2, IMC Chpt. 13

Property Owner Acknowledgement

Print Name _____

Owner Signature _____

Date _____

Installer Information (Lic. No._____)

Installer Name _____

Installer Signature _____

License Holder Name _____

License Holder Signature _____

Date of Installation _____

Please be aware that New Castle County will continue to reserve the right to perform inspections on the replacement appliance installation. Licensed contractors who certify installations that are later found to not meet minimum code standards, will have their self-certification privilege revoked. Should you have any questions regarding this matter, please feel free to contact the Inspections Office at 302-395-5572.