



NEW CASTLE COUNTY

RESIDENTIAL REPLACEMENT BOILER
2015 IMC Self-Certification Form

DEPARTMENT OF LAND USE
87 READS WAY, NEW CASTLE, DE 19720
PHONE: 302-395-5400 • WWW.NCCDELU.ORG

5/26/15
REVISED 4/7/2017
CODE "RRA"

This certification form shall be signed by the Licensed Contractor who performed the installation. Completed forms must be forwarded to the New Castle County Inspections Section at buildinginspections@nccde.org immediately following the installation.

Form section for property information including Lot #, Subdivision, Tax Parcel, Property Address, and HVAC Permit #.

CHECKLIST

Installations shall comply with all applicable New Castle County adopted codes

Specs: \_\_\_\_\_ BTU Manuf. \_\_\_\_\_ Model # \_\_\_\_\_

Fuel type [ ] Natural Gas [ ] LP [ ] Oil

General / Inspection checklist

- General / Inspection checklist items: Pass N/A, Manuf. instructions left with appliance, Manuf. name, model, etc affixed to appliance, Appliance installed in accordance with permit, Lighting fixture installed (attic & under floor), Electrical work installed & inspected if applicable, Chimney and/or vent connector meets code.

- General / Inspection checklist items: Pass N/A, Chimney and/or vent connector minimally pitched & properly sized, Masonry chimneys lined per, Direct-vent, integral & mech. draft systems per code, Condensate disposal installed per code, Access and service space per code, Piping supported per code, Space/water heating systems provided w/sealed protection.

Gas

- Gas checklist items: Pass N/A, Shut off valves installed, Fuel gas piping inspected if req'd, Clearance to combustibles, Combustion air provided, Ignition source elevated in hazardous locations, Oil tank removed if req'd.

Oil

- Oil checklist items: Pass N/A, Shut off valves installed, Fuel oil piping complies with code, Clearance to combustibles meets code, Combustion air provided, Ignition source elevated in hazardous locations, Barometric damper installed, Fuel oil tank and piping installed per code.

Boiler

- Boiler checklist items: Pass N/A, Water supply connection per, Low-water cutoff control installed, Boiler expansion tank installed, Safety valves installed, Pressure relief valve installed.

Building Permit Holder's Signature (or Authorized Rep.)

Date

Print Name

NCC Contractor Registration # (if applicable)

Please be aware that New Castle County will continue to reserve the right to perform inspections on the replacement appliance installation. Licensed contractors who certify installations that are later found to not meet minimum code standards, will have their self-certification privilege revoked. Should you have any questions regarding this matter, please feel free to contact the Inspections Office at 302-395-5572.