RESIDENTIAL REPLACEMENT FORCED AIR FUEL FIRED APPLIANCE

NEW CASTLE COUNTY

2018 IMC Self-Certification Form

DEPARTMENT OF LAND USE
87 READS WAY, NEW CASTLE, DE 19720
PHONE: 302-395-5400 • WWW.NCCDELU.ORG

1/12/2021
CODE "RRA"

This certification form shall be signed by the Licensed Contractor who performed the installation. Completed forms must be forwarded to the New Castle County Inspections Section at buildinginspections@nccde.org immediately following the installation.

LOT # _____ SUBDIVISION_____TAX PARCEL_____

PROPERTY ADDRESS _____

HVAC PERMIT #_____

CHECKLIST

Installations shall comply with all applicable New Castle County adopted codes

Specs: _____ BTU Manuf._____ Model #_____

Fuel type ☐ Natural Gas ☐ LP ☐ Oil ☐ With A/C ☐ A/C not applicable

General / Inspection checklist

Passed	N/A		
☐		Manufacturer's instructions left with appliance	IMC 304.1
☐		Manufacturer's name, model, etc affixed to appliance	IMC 301.6
☐		Appliance installed in accordance with permits	Chapter 6 6.03.013
☐	☐	Lighting fixture installed (attic & under floor spaces)	IMC 306
☐	☐	Electrical work installed & inspected if applicable	DE Title 24 Ch. 14
☐	☐	Chimney and/or vent connector in good condition or replaced	IMC 803
☐	☐	Chimney and/or vent connector minimally pitched & properly sized	IMC 803.10.5, 801.6
☐	☐	Masonry chimneys lined per	IMC 801.16, IFGC 504.2.7, 504.2.9
☐	☐	Direct-vent, integral & mechanical draft systems installed to code	IMC 804
☐		Condensate disposal installed per code	IMC 307
☐		Access and service space per code	IMC 306
☐		Piping supported per code	IMC 305
☐		Air filters located, installed, and of approved type	IMC 605

Gas

Passed	N/A		
☐		Shut off valves installed	IFGC 409.1
☐		Fuel gas piping inspected if required	IFGC 406.1
☐		Clearance to combustibles	IMC 304.9, 308
☐		Combustion air provided	IMC 701
☐	☐	Ignition source elevated in hazardous locations	IMC 304.3
☐	☐	Oil tank removed if required	

Oil

Passed	N/A		
☐		Shut off valves installed	IMC 1307
☐		Fuel oil piping complies with code	IMC 1302
☐		Clearance to combustibles meets code	IMC 304.9, 308
☐		Combustion air provided	IMC 701
☐	☐	Ignition source elevated in hazardous locations	IMC 304.3
☐		Barometric damper installed	IMC 803.6
☐		Fuel oil tank and piping installed per code	IMC Chapter 13

_____ _____

Building Permit Holder's Signature (or Authorized Rep.) Date

_____ _____

Print Name NCC Contractor Registration # (if applicable)

Submit

Please be aware that New Castle County will continue to reserve the right to perform inspections on the replacement appliance installation. Licensed contractors who certify installations that are later found to not meet minimum code standards, will have their self-certification privilege revoked. Should you have any questions regarding this matter, please feel free to contact the Inspections Office at 302-395-5572.